


Status update

# IEA Wind 2200-22-MW Reference Offshore Wind Plants

Samuel Kainz  
Julian Quick  
Christopher Bay

IEA Wind Task 55

Roskilde, DK  
3<sup>rd</sup> December 2024



# Introduction

- Work Package 3 of IEA Wind Task 55: Reference wind plants
- Objective: Design, release, and maintain new land-based and offshore reference wind plants
- Already published: IEA Wind 740-10-MW Reference Offshore Wind Plants<sup>1</sup> based on 10MW machines
- Current efforts: Next generation reference offshore wind plants using IEA 22-MW reference turbines
- Future plans:
  1. Floating reference offshore plants using IEA-22MW or IEA-15MW machines (collaboration with Task 49)
  2. Onshore reference plant using future IEA onshore turbine

	Year 1				Year 2				Year 3				Year 4				Progress	
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4		
<b>WP3: Reference WP</b>																		Report
Offshore fixed-bottom plant	Yellow	Yellow	Yellow	Yellow	Green	Yellow	Yellow	Yellow										
Offshore floating plant					Yellow	Yellow	Yellow	Yellow	Green	Yellow	Yellow	Yellow						
Land-based													Green	Yellow	Yellow	Yellow		
Maintenance	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow		





# Motivation

*“Why do we need reference plants?”*

- Benchmarks to evaluate innovations
- Popular when there is no access to real design + data
- Collaboration among / with industry to minimize use of intellectual property
- Great success for IEA reference turbines → next level: reference wind plants
  - ➔ Holistically defined and broadly applicable wind plants
  - ➔ Extensive and easily accessible information (windIO) on site characteristics, plant design, turbine definition, ...
  - ➔ Allowing for diversified and comprehensive studies with varying analysis and optimization objectives

# IEA Wind 740-10-MW ROWPs

- Based on Borssele III & IV in Dutch-Belgian offshore cluster
- 74 x IEA-10MW turbines
- Optimization objective: maximum AEP
- Two reference layouts (regular / irregular)
- Plant data, optimization code, sample codes for Floris / Pywake publicly available on github
- NREL technical report<sup>1</sup> describing the reference plants in detail





<sup>1</sup> Kainz S, J Quick, M Souza de Alencar, S Sanchez Perez Moreno, K Dykes, CJ Bay, MB. Zaaijer, P Bortolotti (2024): "The IEA Wind 740-10-MW Reference Offshore Wind Plants", IEA Wind TCP Task 55, NREL Technical Report

Ongoing work

# The IEA 2200-22-MW Reference Offshore Wind Plants


# Site description

- Outcome of community survey / discussion in Task-55 meeting in Florence (May'24 before TORQUE)
- Hollandse Kust West (HKW) development zone
- 176km<sup>2</sup>, 53 km from shore
- Abundant data publicly available through Dutch government (Coordinates, infrastructure plans, several lidar for wind, wave measurements, geophysical survey, archeological desk study, ...)
- Consists of three sites, in total ~2.2GW (100 x IEA-22MW), two are sold and being developed:
  1. Ecowende (Shell & Eneco): 693-756 MW
  2. HKW VII (RWE subsidiary): 760 MW
  3. HKW VIII: 700 MW



# Approach

- Develop three sites concurrently while considering the others as neighboring wind farms
- Turbine type: monopile-based IEA 22-MW reference wind turbine
- Optimization objective: Levelized Cost of Energy (LCOE)
- Design variables: Turbine positions (x,y)
- Constraints: Boundaries and minimum turbine spacing (2D)
- Substation positions are fixed (Tennet)
- Optimization setup in TopFarm using SGD algorithm
- Initial layout: random positions within boundaries, will be updated with DTU's "Smart Start"
- Relevant data provided in windIO format
- Python script to load data and run optimization



# Objective function (1/2)

Main impacts on LCOE when varying turbine positions:

## 1. Wake effects


- Modeled through PyWake
- Batankhah 2014 wake model, squared sum superposition, no TI dependance, rotor center effective wind speed

## 2. Support structure

- DTU monopile mass surrogate model<sup>2</sup> to scale monopiles with varying bathymetry
- Based on multiple monopile optimizations (objective: minimum mass) using WISDEM for different rotor types and different site conditions

## 3. Array cabling

- new innovative DTU cabling optimization algorithm ("EDWIN")<sup>3</sup>
- "Gap" parameter control solution time and accuracy






## Objective function (2/2)

$$LCOE = \frac{(MPC + CC + CAPEX_{fix} + LP_d) \cdot CRF + OPEX_a}{AEP}$$

- **AEP** (annual energy production): modeled via PyWake
- **MPC** (monopile costs): mass output from surrogate model translated to cost using ORBIT<sup>3</sup> cost scaling function
- **CC** (cable costs): price per meter cable length (three cable types made available to optimizer)
- Baseline costs. Currently calculated with TUM in-house tool (DETECT), simplification planned. Potential check with industry?
  - **CAPEX<sub>fix</sub>** – fixed investment costs (excl. monopile / array cabling)
  - **LP<sub>d</sub>** – Liquidation proceeds at end-of-life (discounted to present value)
  - **OPEX<sub>a</sub>** – annual O&M costs
- Neglected: taxes and financing
- **CRF** ... Capital Recovery Factor = 1 / Annuity Factor

# Optimization algorithm

- Optimization is performed using TOPFARM Stochastic Gradient Descent algorithm
- This randomly samples the gradient of the objective function while enforcing deterministic constraints



# Gradients


- Applying the quotient rule to our objective function:

$$\partial LCOE = \frac{CRF \cdot (\partial MPC + \partial CC) \cdot AEP - ((CAPEX + LP + MPC + CC) * CRF + OPEX_a) \cdot \partial AEP}{AEP^2}$$

- Required for SGD optimizer (gradient-based algorithm)
- Validated with finite differences
- Monopile surrogate cost versus depth fit using polynomial
- Cable costs are determined as a linear mapping of turbine positions
- PyWake supports AEP gradients

# Preliminary results

Iteration: 0  
 LCOE = 55.11 \$/MWh (+0.00%)  
 AEP = 3493.0 GWh (+0.00%)  
 Cab-Cost = 15,612,177 \$ (+0.00%)  
 MP-Cost = 78,892,135 \$ (+0.00%)



# Next steps

- Define the three sites as inclusion zones
  - Optimize all three sites at once
  - Simplify fixed costs (literature-based instead of model-based)
  - Further test and verify the setup. Particularly:
    - Monopile mass surrogate model: Tune with IEA-22MW reference monopile design? Model created with data for rated power up to 20MW → extrapolation to 22MW?
    - Examine the conservative "TurboPark" wake model
    - Co-operative versus competing layout (and controls?) designs
- ➔ End January '25: Final plant layouts, draft of technical report
- ➔ End February '25: Final version of report
- ➔ March '25: Release report + repository
- ➔ Potential follow-up journal paper using full potential of optimization setup

# Discussion

- General thoughts about optimization approach?
- Is the monopile cost model realistic? Sand banks? Slope constraint?
- Should we rely on the conservative TurboPARK model? Is there a better way to capture these physics?
- Any other cost aspects to consider? Layout-specific O&M costs?
- Anything else to discuss?

Thank you!